

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਉਪ ਮੰਡਲ, ਲੋਨਿਵਿ: ਭ ਤੇ ਮ ਸਾਖਾ,
ਫਿਲੋਰ ਐਟ ਜਲੰਧਰ।

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY
(WATER ANALYSIS REPORT)

REF. NO: -1307

REF. DATE: 20/05/26

Sample provided by :- Guru Nanak Foundation Global School, Urban Estate Phase 1, Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 - 8.5	7.4
5	DISSOLVED SOLIDS (TDS)	500 ppm	132
6	TOTAL HARDNESS (as CaCO_3)	300 mg/l	90
7	ALKALINITY	200 mg/l	92
8	CALCIUM (as Ca^{++})	75 mg/l	13.2
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	48
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per applied tests

DATE: 22/05/26

Deepest Kumar
Analyst
Municipal Corporation Jalandhar
ANALYST

2026 07 09 12:24